

#### **CONTRACT ADDENDUM NO. 2**

# City of Des Moines Kent Des Moines Rd / 16<sup>th</sup> Ave S Pipe Replacement Stormwater Improvement Project

Date of Addendum Issue:

Date of Original Opening:

Date of Revised Opening (per Addendum #1):

April 8, 2024

April 18, 2024

April 22, 2024

Engineer: Owner:

KPG Psomas Inc.

3131 Elliott Ave, Suite 400

Seattle, WA 98121

City of Des Moines
21630 11<sup>th</sup> Avenue S, Suite A
Des Moines, WA 98198

# Notice to All Holders of the Plans and Contract Provisions (Contract Documents):

This Addendum No. 2, containing the following revisions, additions, deletions and/or clarifications is hereby made part to the Plan and Contract Provisions (Contract Documents) for the above-named project. Bidders shall take this Addendum into consideration when preparing and submitting their bids.

Contractors shall acknowledge the receipt of this Addendum No. 2 in the place provided in the Proposal Signature Sheet. Failure to do so may disqualify the Bidder from consideration of its bid.

2 pages of text (including this cover sheet)


### **CONTRACT SPECIFICATIONS**

**Item #1:** Special Provision 7-06.2: Clarification. The following language is added to SP Section 7-06.2.

To clarify, felt liner and glass reinforced fiber liner are both acceptable liners when following SP 7-06.1(1) which references specifications, codes, and standards and approved installation and curing methods specific to liner being installed.

## ALL OTHER REQUIREMENTS OF THE CONTRACT DOCUMENTS REMAIN IN EFFECT.

Addendum No. 2 City of Des Moines Kent Des Moines Rd / 16th Ave S Pipe Replacement Stormwater Improvement Project April 17, 2024



Date:

City Project Manager

Digitally signed by Kelsey Anderson
DN: C=US,
E=kelsey.anderson@psomas.com,
O=KPG Psomas, OU=KPG Psomas,
CN=Kelsey Anderson
Reason: Addendum #2
Date: 2024.04.17 13:35:17-07'00'

Prepared By:	Date: 2024.
	Kelsey Anderson, P.E.
	Project Manager

Checked By:	GM/	Date: 4/17/2024
	Cong Nyouen P.E.	

Thomas Owen Date: 4/17/2024 Approved By: Thomas Owen, P.E., PTOE Acting Public Works Director